

To: Mills, Brian (Environmental)[brian.mills@titan-intl.com]
Cc: Steinman, Ty (Legal)[ty.steinman@titan-intl.com]; Troyanovich, Mike (Legal)[mike.troyanovich@titan-intl.com]; Gazi George (gtsi2000@yahoo.com)[gtsi2000@yahoo.com]; George, Robert (Environmental)[robert.george@titan-intl.com]; 'Woodruff@dmww.com'[Woodruff@dmww.com]; Hylton Jackson[hylton.jackson@dnr.iowa.gov]; Pemberton, Scott[Pemberton.Scott@epa.gov]
From: McCoy, Erin
Sent: Tue 3/28/2017 6:01:43 PM
Subject: RE: Extraction Well #7 at Dico

Brian, thank you for letting me know.



Erin McCoy, P.G. | Remedial Project Manager

EPA Region 7 | Superfund Division | Superfund Remediation Branch

11201 Renner Blvd | Lenexa, KS 66219

Phone: 913.551.7977

mccoy.erin@epa.gov | www.epa.gov

From: Mills, Brian (Environmental) [mailto:brian.mills@titan-intl.com]
Sent: Monday, March 27, 2017 4:44 PM
To: McCoy, Erin <McCoy.Erin@epa.gov>
Cc: Steinman, Ty (Legal) <ty.steinman@titan-intl.com>; Troyanovich, Mike (Legal) <mike.troyanovich@titan-intl.com>; Gazi George (gtsi2000@yahoo.com) <gtsi2000@yahoo.com>; George, Robert (Environmental) <robert.george@titan-intl.com>; 'Woodruff@dmww.com' <Woodruff@dmww.com>; Hylton Jackson <hylton.jackson@dnr.iowa.gov>
Subject: Extraction Well #7 at Dico

Erin, please be notified that extraction well #7 at Dico was not running. I was able to restart the well and it is back in operation.

I have contacted an electrical contractor and the contractor believes that one of the water level sensors may be bad or there may be a bad connection in the electrical wiring for this well. I'm working with the electrical contractor to schedule a date for the contractor to test the water level sensors for proper operation and check for bad electrical connections.

I will keep you updated on the actions taken to fix the issue with the well intermittently shutting off.

Brian Mills

Please Note: The information contained in this message may be privileged and confidential, protected from disclosure, and/or intended only for the use of the individual or entity named above. If the reader of this message is not the intended recipient, or an employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any disclosure, distribution, copying or other dissemination of this communication is strictly prohibited. If you received this communication in error, please immediately reply to the sender, delete the message and destroy all copies of it. Any views or opinions expressed in this message are solely those of the individual sender, except where the sender specifies with authority them to be the views of Titan. Titan reserves the right to monitor both incoming and outgoing e-mails and therefore the sender and recipient of such e-mails should have no expectation of privacy in this regard. Thank You.